

Technical document

Suppliers name				
Name	CARRIER JAPAN CORPORATION			
Address	336 TADEHARA, FUJI-SHI, SHIZUOKA-KEN,			
	JAPAN	1		

 Outdoor unit

 Type
 XCT8 10HP

 name
 38VT022188HTEE

general description of the appliance Multi split type air conditioner

indoor unit				indoor unit(2)					
Type 4way cassette			Туре	4way cassette					
name 40VU024S-8S-TEE			name	40VU024S-8S-TEE					
indoor unit(3)	<u>.</u>			indoor unit(4)					
Type 4way cassette			Туре	4way cassette	4way cassette				
name	name 40VU024S-8S-TEE			name	40VU024S-85	S-TEE			
indoor unit(5)				indoor unit(6)	indoor unit(6)				
Туре	-			Туре	-	-			
name -			name	-					
· · · · · · · · · · · · · · · · · · ·									
indoor unit(7)				indoor unit(8)					
Туре -		Туре	-						
name -			name						
Power consumption of cycling				Efficiency of cycling					
cooling	Pcycc	x , x	kW	cooling	EERcyc	x , x			
-	•			0	•		-		
heating	Pcych	X , X	kW	heating	COPcyc	Х,Х	-		
Degradation co-efficient				Degradation co-efficient					
cooling	Cdc	0,25	-	Heating	Cdc	0,25	-		



				If function applies to heating: Indic	ate the heating se	ason the		
Function(indicate which fund	ction annlies to the	information)		information relates to. Information	-			
i uncion(indicate which turk	cuon applies to the	intornation				•		
	V			season at a time. Include at least	the heating seaso	II Avelage		
cooling	Y			Average(mandatory)	Y			
heating	Y			Warmer(if designated)	N			
				Colder(if designated)	N			
Item	symbol	value	unit	Item	symbol	value	unit	
Design load	Symbol	Value	unit	Seasonal efficiency	Symbol	Value	unit	
cooling	Pdesignc	28,0 kW		cooling	n 00	293,4 %		
•	~	,		cooling	ηsc SEER	,		
heating/Average	Pdesignh	,				7,41 -		
heating/Warmer	Pdesignh	x,x kW		heating/Average	ηsh(A)	179,0 %		
heating/Colder	Pdesignh	x,x kW			SCOP(A)	4,55 -		
				heating/Warmer	ηsh(W)	<u> </u>		
					SCOP(W)	X, X X -		
				heating/Colder	ηsh(C)	X X X , X %		
					SCOP(C)	х,хх -		
Declared capacity for cooling at	tindoor temporature o	P7(10)°C	1	Declared Energy efficiency ratio for	or cooling at index	r temperature		
	i muoor temperature 2				-	remperature		
and outdoor temperature Tj.	Dda	20.00		27(19)°C and outdoor temperature		2.40		
Tj=35°C	Pdc	28,00 kW		Tj=35℃	EERd	3,12 -		
Tj=30°C	Pdc	20,63 kW		Tj=30°C	EERd	5,38 -		
Tj=25°C	Pdc	13,26 kW		Tj=25°C	EERd	8,50 -		
Tj=20°C	Pdc	7,90 kW		Tj=20°C	EERd	15,19 -		
Declared capacity for heating/A	•	oor		Declared coefficiency of performa	-	-		
temperature 20°C and outdoor t				at indoor temperature 20°C and or				
Tj=-7°C	Pdh	14,15 kW		Tj=-7°C	COPd	2,75 -		
Tj=2°C	Pdh	8,62 kW		Tj=2°C	COPd	4,35 -		
Tj=7°C	Pdh	5,89 kW		Tj=7°C	COPd	6,61 -		
Tj=12°C	Pdh	6,39 kW		Tj=12°C	COPd	7,69 -		
Tj=bivalent temperature	Pdh	14,15 kW		Tj=bivalent temperature	COPd	2,75 -		
Tj=operation limit	Pdh	13,23 kW		Tj=operation limit	COPd	1,65 -		
Declared capacity for heating/Warmer climate, at indoor				Declared coefficiency of performa	-			
temperature 20°C and outdoor t				at indoor temperature 20°C and or				
Tj=2°C	Pdh	x,xx kW		Tj=2°C	COPd	X, X X -		
Tj=7°C	Pdh	x,xx kW		Tj=7°C	COPd	X, X X -		
Tj=12°C	Pdh	x,x x kW		Tj=12°C	COPd	х,хх -		
Tj=bivalent temperature	Pdh	x,xx kW		Tj=bivalent temperature	COPd	x, x x -		
Tj=operation limit	Pdh	x,xx kW		Tj=operation limit	COPd	х,хх -		
Declared capacity for heating/C		or		Declared coefficiency of performance for heating/Colder climate,				
temperature 20°C and outdoor t				at indoor temperature 20°C and or	•			
Tj=-7°C	Pdh	x,x x kW		Tj=-7°C	COPd	х,хх -		
Tj=2°C	Pdh	x,xx kW		Tj=2°C	COPd	х,хх -		
Tj=7°C	Pdh	x,xx kW		Tj=7°C	COPd	х,хх -		
Tj=12°C	Pdh	x,xx kW		Tj=12°C	COPd	х,хх -		
Tj=bivalent temperature	Pdh	x,xx kW		Tj=bivalent temperature	COPd	х,хх -		
Tj=operation limit	Pdh	x,xx kW		Tj=operation limit	COPd	х,хх -		
Tj=-15°C	Pdh	x,x x kW		Tj=-15°C	COPd	х,хх -		
Bivalent temperature				Operation limit temperature				
heating/Average	Tbiv	-7 °C		heating/Average	Tol	-25 °C		
heating/Warmer	Tbiv	х,хх °С		heating/Warmer	Tol	х,хх °С		
neuting/warner				heating/Colder	Tol	x,xx °C		
heating/Colder	Tbiv	х,хх °С						
heating/Colder				· · · · ·				
heating/Colder Electric power input in power m	odes other than "on m	node"		Seasonal electricity consumption	005		11-1-	
heating/Colder Electric power input in power m off mode	odes other than "on m Poffc	node" 0,014 kW		Seasonal electricity consumption cooling	QCE		/h/a	
heating/Colder Electric power input in power m off mode stanby mode	odes other than "on m Poffc Psbc	node" 0,014 kW 0,014 kW		Seasonal electricity consumption cooling heating/Average	QHE/A	4922 kW	/h/a	
heating/Colder Electric power input in power m off mode	odes other than "on m Poffc	node" 0,014 kW		Seasonal electricity consumption cooling		4922 kW x kW		



Electric power input in power modes other than "on mode"				Supplementary heater				
off mode	Poffh	0,022	kW	back-up heating capacity	elbu	2,00	kW	
stanby mode	Psbh	0,022	kW					
thermostat-off mode	Ptoh	0,022	kW	Refrigerant				
crankcase heater mode	Pckh	0,001	kW	Туре		R410A		
<u> </u>				Weight		6,0	kg	
Capacity control(indicate one of thr	ree options)			Global warming potential	GWP	2088	kgCO2eq.	
Fixed	N							
strage	N			Rated air flow				
variable	Y			Rated air flow(outdoor/cool)		10500	m3/h	
	•			Rated air flow(outdoor/heat)		10500	m3/h	
Sound power level							•	
Sound power level(outdoor/cool)		79,0	dB(A)	outdoor unit				
Sound power level(outdoor/heat)		82,0	dB(A)	dimension	height	1690	mm	
· · · · ·				⇒	width	990	mm	
					depth	780	mm	
				weight	-	209	kg	
				<u> </u>		÷	+ •	
Harmonised standard EN14511-3 : 2013								
<u> </u>								
Calculation methods		PrEN 14825 :	2016					
Measurement standards								
		•						
Contact details for obtaining Importer/Distributor in EU:								
more information								

Where the information included in the technical documentation file for a particular air conditioner model has been obtained by calculation on the basis of design, or extrapolation from other equivalent appliances, or both, the documentation shall include details of such calculations or extrapolations, or both, and of tests undertaken by suppliers to verify the accuracy of the calculations undertaken. The information shall also include a list of all other equivalent appliance models where the information was

obtained on the same basis.